


## 2004

- Summer 2004 – former CUC lab manager on trial for falsifying coliform data
- CUC has new lab manager
- Nov 2004 – submits monthly results for October
- 6 (+) E. Coli – lots of TC (+)
- Chaos

Saipan

## Why all the TC/EC (+)

- Tried to figure out what was going on
- Made a map of all E Coli (+)
- All over the island
- Entered all the results for October in a [spreadsheet](#)



Saipan

## Saipan

- Results show Cl residual > 0.2 mg/l good
- CUC ran out of gas chlorine
- Were “juggling” cylinders between sites

Saipan