



3K ICE & WATER

Table 1. Inorganic Contaminant Data for 3K ice & Water.

CONTAMINANTS	Maximum Contaminant Level		Sample Collection Date	Levels detected	Was there an MCL?		Probable Sources of Contaminants
	Goal	Allowed			Yes	No	
Inorganic Contaminants							
Nitrate (ppm)	10	10	12/16/13	0.32		X	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
			10/17/14	0.4		X	

Table 2. Lead & Copper Results (Pb & Cu) 2014.

CONTAMINANTS	Action Level	MCLG	Detected Levels		Was there an Exceedance		Probable Sources of Contaminants
			Highest Average (90th % tile)	Levels detected	Yes	No	
Inorganic Contaminants							
Lead (ppb) Collected Date: 8/13-15/14	15	0	0.52	ND to 0.53		X	Corrosion of household plumbing; Erosion of natural deposits
Copper (ppm) Collected Date: 8/13-15/14	1.3	1.3	0.012	0.0085 to 0.013		X	Corrosion of household plumbing; Erosion of natural deposits; Leaching from wood preservatives

UNITS:
ppb - parts per billion
ppm - parts per million

KEY:
MCLG—Maximum Contaminant Level Goal
ND—None Detected.



3K ICE & WATER
MP 0000176
P.O BOX 324
TINIAN, MP 96952
(670) 433-0003

Contact person:
Mr. Julio Mojica

July 1, 2015
By
Quality Water, Inc.



The Consumer Confidence Report (CCR) 2014 gives a summary of the quality of water provided by **3K ICE & WATER** for 2014. This contains relevant information on the water source, the levels of contaminants detected, and compliance with drinking water rules, as well as additional educational material. This CCR is prepared to: 1) inform the consumer of the quality of water, 2) help them better understand the significance of safe drinking water, and 3) encourage them to protect their drinking water sources.

IMPORTANT

This report contains important information about your drinking water. Translate it, or speak with someone who understands it.

Ang ulat na ito ay naglalahad ng mahalagang impormasyon tungkol sa inyong iniinom na tubig. Mangyaring ipasalin ito, o talakayin ito sa sinumang nakakaunawa.

この情報は重要です。
翻訳を依頼してください。

이 안내는 매우 중요합니다.
본인을 위해 번역인을 사용하십시오.

此份有关你的食水报告,内有重要资料和讯息,请找他人替你翻译及解释清楚。

WATER SOURCE INFORMATION



3K ICE & WATER established in April of 2009 and situated in San Jose village, Tinian. Our company refills & sells five gallon bottled water and ice cubes. We are also in the market of assorted items like groceries, school and office supplies and hardware products. We obtain water from Commonwealth Utilities Corporation (CUC). We have two CUC water metered connection

volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.



- **Radioactive contaminants**, which can be naturally-occurring or be the result of oil and gas production.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits from contaminants in bottled water which must provide the same protection for public health.

VIOLATIONS FOR THE YEAR 2014



3K ICE & WATER did all the Total Coliform testing requirements for 2014 and obtained no MCL violation. We also collected 5 Lead & Copper (Pb & Cu) sampling requirement on August 13 to 15, 2014 at sites designated and approve by BECQ. Nitrate was also collected at the Entry Point (17601) on October 17, 2014. Phase II/V (Inorganic and Inorganic Contaminants) samples was last monitored at

the Entry Point (Sample tap# 17602) on December 16, 2013. Results for these parameters show that no MCL was detected (see results on table 1 on page 8).

This CCR 2014 is available at **3K Ice & Water** in San Jose. For questions, comments and suggestions please feel free to call **3K Ice & Water** at 433-0003 and look for **Julio Mojica** or write to **3K Ice & Water P.O Box 324, Saipan, MP 96950**.

and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people, however, may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA / CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.



Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and

to supply our water system. Chlorinated CUC water is filtered using a spun type sedimentation and granular activated carbon (GAC) and passes thru the reverse osmosis (RO) membrane where contaminants are filtered and removed. Disinfection is achieved thru Ultra Violet Lamp. We are required to submit water samples for microbiological (Total & Fecal Coliform) and chemical analysis based on the CNMI Drinking Water Regulations. Samples for routine microbiological testing are submitted monthly to monitor whether harmful bacteria are present in the water and to determine whether proper disinfection procedure is met. Chemical tests are done to monitor for organic and inorganic contaminants and take treatment techniques where applicable, and to ensure that drinking water reaches the consumer in safe and acceptable quality.



KEY TERMS AND DEFINITION

Maximum Contaminant Level (MCL)

- the highest level of contaminant that is allowed in drinking water. MCL's are as set as close to the MCLG's as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG)

- the level of a contaminant in drinking water below which there is no known or expected risk to health. This level allows margin of safety.

Maximum Residual Disinfectant Level (MRDL)

- the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG)

- the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Action Level (AL)

- the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

None Detected (ND)

- means detected value is below reporting level.

Total Coliform

- Coliforms are a family of bacteria, naturally present in the environment. They are used as indicator organisms. Their presence indicates that other potentially harmful bacteria may be present such as *E.coli*. This would indicate fecal contamination in water. When coliforms are detected more than the allowed limit, it is a warning or an indication of potential problems. Samples that turn out positive are required to be collected for four repeat samples within 24 hours and five routine samples the following month.



Treatment Technique

- a required process intended to reduce the level of a contaminant in drinking water.

HEALTH INFORMATION ON CHEMICAL CONTAMINANTS



3K ICE & WATER is required to monitor for Phase II/V (Inorganic & Organic Contaminants) and Lead & Copper (Pb & Cu) once every three years at sites designated and approved by the Bureau of Environmental & Coastal Quality (BECQ). Nitrate/

Nitrite(NO₃) is being monitored on an annual basis.

Nitrate is usually obtained from leaching septic tanks, sewage, run-off from fertilizer use and erosion of natural deposits. Infants below the age of six months who drink water containing

nitrate or nitrite in excess of the MCL could become seriously ill, and if left untreated, may die. Symptoms may include shortness of breath and blue-baby syndrome.

Lead and copper are regulated in a Treatment Technique which requires systems to take tap water samples at sites with lead or copper pipes that have lead solder or are served by lead service lines.

Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short period of time could experience gastrointestinal diseases or suffer kidney or liver damage after many years. People with Wilson's Disease should consult their personal doctor.

Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

The Stage 1 DDBPR requires systems which use chemical disinfections procedures to collect samples from sites with the maximum residence time during the warmest months of the year. One sample was collected in 2004 to check for the presence of Trihalomethanes (THM) and Haloacetic acid (HAA). Some people who drink water containing HAA's in excess of the MCL over many years may have an increased risk of getting cancer while some who drink water containing THM's in excess of the MCL over many years may experience problems with their liver, kidneys or central nervous systems, and may have an increased risk of getting cancer.

ADDITIONAL INFORMATION ON WATER

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants